



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2024/003Dated: 10.04.2024

It is certified that an inspection team headed by Dr. Ravi Shankar Singh, Incharge Medical Officer (Name of Officers with designation) from Community Health Centre, Dwarahat (Almora) (Name of Department/ Office) inspected the Universal Convent School, Tehsil Road, Dwarahat, (Distt- Almora), Uttarakhand (Name & Address of the school) on 10.04.2024 (date of inspection) & found that the Universal Convent School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of 10/4/2024 To 09/04/2025

Signature with Seal: Name : Dr. Ravi Shankar SinghDesignation : Incharge Medical OfficerName & Address of : Community Health Centre
the Office / Department: Dwarahat (Almora)

To,

Universal Convent School
Tehsil Road, Dwarahat
(Distt- Almora), Uttarakhand

(Name & Address of the Institution)



"NABL Recognized
Sub Divisional Water Quality Testing and Monitoring Laboratory, Haldwani
Government Drinking Water Testing Laboratory"
Ph (O): 05946 – 220776, E-mail: eehal-ujs-uk@nic.in


Test Report ID: 04/UJS/SDLWQTML/2024-25


Dated: 24/04/2024

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	UNIVERSAL CONVENT SCHOOL Dwarahat-Almora.		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Universal Convent School Dwarahat- Almora.
Reference Sample Identification:	SDLWQTML/UJS/UCS-04		Date of Start of Analysis: 22/04/2024 Date of End of Analysis: 23/04/2024
Date and Time of Sample Received: 22/04/24&11:40AM	Sample Collected by:	Customer	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit(BIS) in the Absence of alternative source	Std. Test Method
1	pH	8.11	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2	Total Dissolved Solids (TDS), mg/L	144	500	2000	IS 3025 Pt-16-2017
3	Turbidity, NTU	0.42	1	5	IS 3025 Pt-10-2017
4	Total Alkalinity (as CaCO ₃), mg/L	126	200	600	IS 3025 Pt-23: 2019
5	Total Hardness (as CaCO ₃), mg/L	120	200	600	IS 3025 Pt-21: 2002
6	Chloride, mg/l	4.4	250	1000	IS 3025 Pt-32 : 2019
7	Calcium (as Ca), mg/L	40.8	75	200	IS 3025 Pt-40 : 2019
8	Magnesium (as Mg), mg/L	4.37	30	100	APHA 23rd Ed.-3500-MgB: 2017
9	Colour, Hazen	5	5	15	IS 3025 Pt-04 : 2021
10	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018


(Chemist)


(Technical Manager)
TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



Sub Divisional water Quality Testing and Monitoring Laboratory, Haldwani
Government Drinking Water Testing Laboratory”
Ph (O): 05946 – 220776, E-mail: eehal-ujs-uk@nic.in


Test Report ID: 04A/UJS/SDLWQTML/2023-24


Dated: 24/04/2024

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	UNIVERSAL CONVENT SCHOOL Dwarahat-Almora.		
Product Description	Drinking Water	Sample Description	One Water Sample collected from Universal Convent School Dwarahat-Almora.
Reference Sample Identification:	SDLWQTML/UJS/UCS-04		Date of Start of Analysis: 22/04/2024
			Date of End of Analysis: 23/04/2024
Date and Time of Sample Received: 22/04/24&11:40AM	Sample Collected by:	Customer	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS) as per IS 10500:2012	Permissible Limit (BIS) in the Absence of alternative source IS 10500:2012	Std. Test Method
BACTERIOLOGICAL PARAMETERS					
1.	<i>Total Coliform, MPN/100ML</i>	ABSENT	Absent	Absent	APHA 23 rd ED-9223-D
2.	<i>E.coli, MPN/100ML</i>	ABSENT	Absent	Absent	APHA 23 rd ED-9223-D


(Chemist)


(Technical Manager)
TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.